

Town of Ashford Swimming Pool Checklist:



- Plot Plan showing distances to lot lines, buildings, well, and septic.
- Eastern Highlands Health District B-100 Approval
- Approval from the Planning & Zoning Commission
- All 125V receptacles must be GFCI protected.
- Power receptacle to circulation pump no closer than 5', no more than 10; from the inside walls of pool, accompanied by twist lock with shut off.
- One general purpose outlet no closer than 10', no more than 2' from inside walls of swimming pool.
- Bonding of all metal parts within 5' horizontally of inside walls of pool; minimum #8 solid copper wire.
- Pool pump time clock, pool water should be set to turnover at least once every 18 hours.
- Pool alarm
- Door alarm if enclosure includes house.
- Pool barrier should be a minimum 48" above grade. (ground?)
- Maximum 2" opening between fence and ground.
- Openings in barrier should be less than 4"
- Access gate, self-closing with locking device, self-latching, opening away from pool.
- Release on pool side of gate at least 3" below top of gate. No opening greater than 1/2 inch within 18" of release mechanism.
- If the wall of dwelling serves as part of the pool barrier:
 - Power safety cover
 - Door alarm
 - All doors with direct access must be self-closing and self-latching. Intriguing
- Pool ladder for above-ground or in-ground pool shall be surrounded by a barrier with a self-closing gate.
- Protect against user entrapment:
 - ANSI approved suction cover
 - Atmospheric vacuum relief system
 - 2 suction outlets-minimum separation of 3"
 - Vacuum or pressure cleaner fittings-accessible at least 6" not more than 12" below the minimum water level.

